

Monthly Extinguisher Checks

Once each month please check the extinguisher(s) in your area. Please be sure to do the following:

Check the Fire Extinguisher

- Check that it is in the appropriate location
- Check that the safety seal and pin are secured
- Check the Dial (if it has one) - the pointer should be in the 'Green Zone'

Check the Yellow Tag

- Place an 'X' in the appropriate box to indicate the month (also in the column for that year) No signature is necessary.

Note: If the yellow tag is missing, call EH&S for a new one.

Call EH&S at 777-2211 if you have any questions or concerns.

Thank you for your assistance in keeping the monthly inspections up to date.